



NOTE:

1. No tap to be made within 30" of a joint or fitting on C.I.P. or D.I.P.
2. Tap on AC and P.V.C. pipe shall be made 3' minimum from any coupling or fitting.
3. Contractor to install thrust block behind and under tapping sleeve.
4. Tapping Sleeves shall be Smith Blair 663-316SS, JCM 432-SS316 all 316 stainless steel or approved equal; and Tapping Valves shall be Mueller flange x mechanical joint or approved equal.
5. When cathodic protection is required, do not connect bond cables to a stainless steel tapping sleeve.

NOT TO SCALE

STANDARD DETAIL	CITY OF BRISBANE DEPARTMENT OF PUBLIC WORKS	
	EXCAVATION FOR TAPPING SLEEVES & VALVES	W-5
DATE: 08/08/23		